



Legenda

- Grup de filtroventilare, Q=450 mc/h;
- Conducta de aspiratie pana la ventilator OL 150mm;
- Canal de aer de introducere OL-Zn Ø125 mm;
- Supapa de suprapresiune tip S-00;
- Grila introducere aer filtrat;
- Priza de aer brut;
- Grila aer brut;



Verificator	Nume	Semnatura	Cerinta	Referat / Expertiza nr. / Data
Verificator/Expert				
Proiectant general:				
S.C. PROCONDENTIS S.R.L.				
PROIECTANT DE SPECIALITATE:				
S.C. AIR - PROECTS S.R.L.				
12/21/02/2013				
CIF: 3603328				
Specificatie	Nume	Semnatura	Scara:	Faza:
Set Proiect	arh. Stefana Gonciar		1:100	D.T.A.C+
Proiectat	ing. Luciu Razvan Silviu			P.Th
Desenat	ing. Luciu Razvan Silviu		sept 2016	Plansa nr.
INSTALATIE DE VENTILARE				V1